

PRNC-APWO 11345/2 (10-64)

REPORT FORMAT

(to be reproduced as required)

RCS

ENGMC-D(OT)577

ENG FORM 3706 (OT)

1 NOV 63

WATER AND SEWERAGE FACILITIES SURVEYSample Survey No. 11111
(As shown on List of Buildings)Date prepared 7 SEPT 65SECTION A. - FACILITY IDENTIFICATION
(Use latest NFSS or Updating Survey Data)

1. Name of facility DISC BLDG
2. Address 1801 K ST NW WASH DC
3. S.L. 22110058 P.O. BC FAC. NO. 02934 USE 51
(w/Alpha part, if approp.)

SECTION B. - SHELTER SPACES IN FACILITY
(Use latest NFSS or Updating Survey Data)

1. Number of existing PF Category 2-8 shelter spaces 1332
2. Number of improvable ("Added") shelter spaces —

SECTION C. - WATER AVAILABLE IN SUPPLY SYSTEMS

(Enter for each of the systems listed below, gallons of water available in the same building as the shelter. These quantities are to exclude any water presently stored in CD drums as part of the fallout shelter stocks.)

1. Normal Supplies (Including Plumbing System, Only):

<u>Source</u>	<u>Col. (1)</u> <u>Potable</u>	<u>Col. (2)</u> <u>Non-Potable</u>
a. Piping (hot and cold water supply)	* <u>30</u>	<u> </u>
b. Storage Tanks	<u> </u>	<u> </u>
c. Hot Water Tanks	<u>500</u>	<u> </u>
d. Toilet and Urinal Tanks	<u>120</u>	<u> </u>
e. Indoor Pools and Fountains	<u> </u>	<u> </u>
f. Other	<u> </u>	<u> </u>
g. TOTAL (Gallons)	<u>650</u>	<u>0</u>

SECTION 1 (Con't)

2. Heating and Air Conditioning Systems:

<u>Source</u>	<u>Col.(1) Potable</u>	<u>Col.(2) Non-Potable</u>
a. Heating System*		
(1) Piping and Radiators	_____	_____
(2) Boilers and Tanks	_____	200
(3) Other	_____	_____
b. Air Conditioning System*		
(1) Piping and Coils	_____	_____
(2) Tanks and Cooling Equipment	_____	_____
(3) Other	_____	_____
	0	200

c. TOTAL (Gallons)

*If totals are readily available, individual breakdowns within a and b are not required.

3. Fire Protection System:

a. Piping

b. Storage

c. TOTAL (Gallons)

_____	_____
_____	_____
0	0
650	200

4. TOTAL (C1, C2, and C3, above) Gallons

0	0
---	---

5. Wells, if available, rated gal/min:

Remarks: (Source of data; type of contaminant, if readily available; brief description of well or spring including pump, power, and estimated reliability other pertinent items).

SECTION D - COST ESTIMATES

(Enter cost estimates for making available to shelterees the total quantities of potable and non-potable water shown in Columns (1) and (2) of Section C. Estimates are for planning purposes, only, and will be based upon the best on-site information readily available. Include under "Remarks" a brief description of modifications and major features contributing to the costs. If desired, a simple sketch may be attached)

1. Potable Water:

Source

Cost in Dollars

a. Normal Supplies:

\$ 125

Remarks: (1) 2" CHECK VALVE (1) 1/2" DRAIN COCK

IN CITY MAIN CONNECTION

b. Heating and Air Conditioning Systems:

\$

Remarks:

c. Fire Protection System:

\$

Remarks:

d, TOTAL (a + b + c, above):

\$ 125

e. Wells (enter cost to make available the capacity shown in Section C5. An auxiliary power source must be included if normal power is obtained from external sources. The requirement for emergency power for water supply is a departure from the "power on" assumption used during the NFSS.)

\$ 0

Remarks:

SECTION D (Con't)

2. Non-Potable Water:

(Enter costs to make available the quantities of non-potable water shown in Section C. Treatment to make water potable will not be considered.)

<u>Source</u>	<u>Cost in Dollars</u>
a. Normal Supplies:	\$ _____
Remarks: _____	

b. Heating and Air Conditioning Systems:	\$ _____
Remarks: _____	

c. Fire Protection System:	\$ _____
Remarks: _____	

d. TOTAL (a + b + c, above):	\$ 0
e. Walls (enter cost to make available the capacity shown in Section C5. An auxiliary power source must be included if normal power is obtained from external sources. The requirement for emergency power for water supply is a departure from the "power on" assumption used during the NFSS.)	\$ 0
Remarks: _____	

SECTION E - SEWERAGE SYSTEMS

(Section E will be completed only when quantities are shown in the "Potable" column in Section C)

1. Estimated sewage quantity:

1332 Gal/day

(Use 1 gal/day/space for the number of shelter spaces shown in Item B-1. Note: This figure is assumed for the purposes of this survey only, and includes an allowance for flushing).

2. Estimated capacity of sewer main(s) from building:

480,000 Gal/day

(Include existing sanitary, storm and/or other sewer mains which operate by gravity flow, only. Do not include flow from a sewage lift station in building unless stand-by power is available for its operation).

3. Water closets available to shelters:

30 Units

(Include all water closets within or accessible to the shelter areas in the building without direct exposure of personnel to radiation).

4. Estimated modification costs:

\$0

(Modifications will be considered only when entry in Item 2 is less than Item 1, above; or when shelter area(s) have no access to a gravity sewer or storm drain without direct exposure of personnel to radiation. Include modifications, such as the addition of a "wye" or "tee" for access into the line. Do not include items such as major extensions to or re-routing of existing lines, or addition of pumps or power for pumping. Cost estimates are for planning purposes, only and will be based upon the best on-site information readily available. If desired, a simple sketch may be attached).

Remarks: (Include brief description of proposed modifications and statement as to remaining deficiency, if any, to meet requirement in Item 1, above).
